



Kansas Department of Health and Environment – Bureau of Air
 1000 SW Jackson, Suite 310, Topeka, Kansas 66612
 Phone: (785) 296-6422 Fax: (785) 296-7455

**Existing Compression Ignition (CI) RICE located at an area source of HAPS
 40 CFR Part 63, Subpart ZZZZ**

Engine Type	Requirements – Table 2d & 40 CFR 63.6625	Performance Testing Tables 4 & 5	Subsequent Performance Tests-Table 3	Notification and Report Submission	Other Requirements
Emergency or black start CI	- change oil/filter & inspect hoses/belts every 500 hrs or annually - inspect air cleaner every 1000 hrs or annually -Non-resettable hour meter	NA	NA	Annual report may be required – see Table 7 – Requirements for Reports	<ul style="list-style-type: none"> • Fuel Requirements 40 CFR 63.6604 • General Compliance 40 CFR 63.6605 • Monitoring/Installation/Collection/Operation & Maintenance 40 CFR 63.6625 • Records 40 CFR 63.6655
Non-Emergency CI ≤ 300 hp	-change oil/filter every 1000 hrs or annually - inspect hoses/belts every 500 hrs or annually -inspect air cleaner every 1000 hrs or annually	NA	NA	NA	<ul style="list-style-type: none"> • General Compliance 40 CFR 63.6605 • Monitoring/Installation/Collection/Operation & Maintenance 40 CFR 63.6625 • Records 40 CFR 63.6655
Non-Emergency CI 300< hp ≤500 hp	-Limit CO to 49 ppmvd @ 15% O ₂ – or – reduce CO emissions by 70% or more -Crankcase ventilation system	Initial test due 180 days after compliance date	NA	<ul style="list-style-type: none"> • Initial Notification • Notification of Compliance Status • Semi-annual report submission 	<ul style="list-style-type: none"> • Fuel Requirements 40 CFR 63.6604 • General Compliance 40 CFR 63.6605 • Performance Testing Procedures 40 CFR 63.6620 • Monitoring/Installation/Collection/Operation & Maintenance 40 CFR 63.6625 • Records 40 CFR 63.6655
Non-Emergency CI > 500 hp	-Limit CO to 23 ppmvd @ 15% O ₂ – or – reduce CO emissions by 70% or more -Crankcase ventilation system	Initial test due 180 days after compliance date	Every 8760 hours or 3 yrs, whichever comes first	<ul style="list-style-type: none"> • Initial Notification • Notification of Compliance Status • Semi-annual report submission 	<ul style="list-style-type: none"> • Fuel Requirements 40 CFR 63.6604 • General Compliance 40 CFR 63.6605 • Performance Testing 40 CFR 63.6620 & 40 CFR 63.6625 • Monitoring/Installation/Collection/Operation & Maintenance 40 CFR 63.6625 • Records 40 CFR 63.6655

The owner/operator shall comply with all applicable provisions of 40 CFR Part 63, if a conflict exists between references in this document and the regulation, the regulation shall take precedence