

## **AIR EMISSION SOURCE CONSTRUCTION PERMIT**

**Source ID No.:** 0510057

**Effective Date:** DRAFT, 2014

**Source Name:** Midwest Energy, Incorporated

**SIC Code:** 4911, Electric Services

**NAICS Code:** 221112, Fossil Fuel Power Generation

**Source Location:** 1713 230<sup>th</sup> Avenue  
SE  $\frac{1}{4}$  Section 7, Township 13S, Range 18W, Ellis County  
Hays, Kansas 67601

**Mailing Address:** 1330 Canterbury Rd.  
P.O. Box 898  
Hays, Kansas 67601

**Contact Person:** Mr. William Dowling  
Telephone: (785)625-1432

**This permit is issued pursuant to K.S.A. 65-3008 as amended.**

### **I. Description of Activity Subject to Air Pollution Control Regulations**

Midwest Energy, Inc. plans to install up to three new 9.34 megawatts (MW) spark ignition Wartsila four stroke lean burn reciprocating internal combustion engine (RICE) electric generating units (EGUs) plus auxiliary equipment at their existing Goodman Energy Center Facility in Ellis County, Kansas. The existing Goodman Energy Center has nine RICE (8.44 MW each) and associated equipment on site, and is located approximately four miles northwest of Hays, Kansas. The Project will have a total nominal power output of approximately 28 megawatts (MW) and will be fired by pipeline quality natural gas. The Project will also include a one (1) million Btu per hour (MMBtu/hr) dew point gas heater, a 100 horsepower (hp) emergency diesel fire pump, a 250 kilowatts (kW) emergency diesel generator, a 200 gallon fuel oil storage tank, and a 20 gallon fuel oil storage tank.

The potential emissions of oxides of nitrogen (NO<sub>x</sub>), carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>), volatile organic compounds (VOCs), particulate matter (PM), PM less than 10 microns (PM<sub>10</sub>), and

hazardous air pollutants (HAPs) have been reviewed and the proposed project is subject to the provisions of **K.A.R. 28-19-300 (Construction permits and approvals; applicability)** because the potential emissions for PM and PM<sub>10</sub> are above the permitting thresholds.

The Project is subject to the provisions of **K.A.R. 28-19-720, New Source Performance Standards (NSPS)**. The emergency fire pump and emergency diesel generator are subject to the requirements of 40 CFR 60, Subpart III, Standards of Performance for Stationary Compression Ignition (CI) Internal Combustion Engines. The RICE EGUs are subject to the requirements of 40 CFR Part 60, Subpart JJJJ, Standards of Performance for Stationary Spark Ignition (SI) Internal Combustion Engines.

The addition of the Project to the existing facility will make the Goodman Energy Center a major source of HAPs (greater than 25 tons per year of total HAPs and greater than 10 tons per year of any single HAP). The Project is subject to the provisions of **K.A.R. 28-19-750, Hazardous air pollutants; maximum achievable control technology**, because the estimated potential-to-emit (PTE) of HAPs from the facility is greater than 10 tons annually for a single HAP, and the estimated PTE of all HAPs in the aggregate is greater than 25 tons/year. The three Wartsila RICE EGUs are subject to 40 CFR Part 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines. The emergency generator and emergency fire pump will be affected sources under Subpart ZZZZ. Those engines will be subject only to the requirements of 40 CFR Subpart III based on their classification as new emergency stationary RICE with a site rating of less than or equal to 500 brake hp located at a major source of HAP emissions. The gas heater is subject to 40 CFR Part 63, Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters.

On November 29, 2010, **K.A.R. 28-19 350, Prevention of Significant Deterioration (PSD) of Air Quality, which adopts by reference 40 CFR Part 52.21**, was amended to adopt language from 75 Federal Register 61606 and 61607, which amended 40 CFR 52.21, *Prevention of Significant Deterioration (PSD)* to incorporate Greenhouse Gases (GHGs) regulatory provisions. New sources emitting GHGs in excess of 100,000 tons/yr on a carbon dioxide equivalent (CO<sub>2</sub>e) basis and also exceeding 100/250 tons/yr on a mass basis are subject to PSD permitting requirements for their GHG emissions. For those affected facilities, Best Available Control Technology (BACT) is to be determined for GHG emissions.

The facility is a new major stationary source for at least one regulated pollutant (GHGs) and subject to the requirements of 40 CFR 52.21 as adopted under K.A.R. 28-19-350. Potential emissions indicate that the project will be categorized as a major modification at an existing major source, as a result the project will be subject to PSD construction permit review. Therefore, the potential emissions of CO<sub>2</sub>e, NO<sub>x</sub>, CO, SO<sub>2</sub>, VOC, PM, PM<sub>10</sub>, particulate matter less than 2.5 microns (PM<sub>2.5</sub>), lead, and sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>) were evaluated. The PTE PM, PM<sub>10</sub>, PM<sub>2.5</sub>, and CO<sub>2</sub>e were determined to be above the PSD significance thresholds.

Pursuant to PSD requirements, an air dispersion modeling impact analysis, an additional impact analysis, and a BACT determination were conducted as a part of the construction permit application process. An air dispersion modeling impact analysis was performed for PM<sub>10</sub> and PM<sub>2.5</sub>.

BACT-based emission limitations were determined for all emission units and activities which have the potential to emit PM, PM<sub>10</sub>, PM<sub>2.5</sub> and CO<sub>2</sub>e.

## **II. Significant Applicable Air Pollution Control Regulations**

- A. K.A.R. 28-19-11, Exceptions due to breakdown or scheduled maintenance – as applied to state regulations K.A.R. 28-19-30 through 32 and K.A.R. 28-19-650.
- B. K.A.R. 28-19-30 through 32, Indirect heating equipment emissions.
- C. K.A.R. 28-19-275, Special provisions; acid rain deposition.
- D. K.A.R. 28-19-300, Construction permits and approvals; applicability.
- E. K.A.R. 28-19-350, which adopts by reference 40 CFR 52.21, Prevention of significant deterioration of air quality.
- F. K.A.R. 28-19-500, Operating permit; applicability.
- G. K.A.R. 28-19-650, Emissions opacity limits.
- H. K.A.R. 28-19-720, which adopts by reference 40 CFR Part 60, New Source Performance Standards.
- I. K.A.R. 28-19-750, which adopts by reference 40 CFR Part 63, National Emission Standards for Hazardous Air Pollutants.
- J. 40 CFR Part 60, Subpart A, General Provisions.
- K. 40 CFR Part 60, Subpart IIII, Standards of Performance for Stationary Compression Ignition Internal Combustion Engines.
- L. 40 CFR Part 60, Subpart JJJJ, Standards of Performance for Stationary Spark Ignition Internal Combustion Engines.
- M. 40 CFR Part 63, Subpart A, General Provisions.
- N. 40 CFR Part 63, Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.
- O. 40 CFR Part 63, Subpart DDDDD, National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters.

### **III. Air Emission Unit Technical Specifications**

The following equipment or equivalent is approved:

- A. Three new spark ignition RICE EGUs (Wartsila model 20V34SG), used to generate electricity. The generating capacity of each EGU will be 9.34 megawatts (approximately 12,526 BHP). Each EGU shall be equipped with a selective catalytic reduction (SCR) system and an oxidation catalyst, and shall burn only pipeline quality natural gas for fuel. The EGUs are subject to the

requirements of 40 CFR Part 60 Subpart JJJJ and 40 CFR Part 63 Subpart ZZZZ. The EGUs are subject to the requirements of K.A.R. 28-19-350, Prevention of Significant Deterioration (PSD) of Air Quality, which adopts by reference 40 CFR 52.21. The EGUs are subject to BACT for PM, PM<sub>10</sub>, PM<sub>2.5</sub>, and CO<sub>2e</sub>.

- B. One compression ignition emergency fire pump engine (engine make and model to be determined), rated at 100 HP, which shall burn only ultra-low sulfur diesel (ULSD, 15 ppm sulfur or less). This unit is subject to the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. This fire pump is subject to the requirements of K.A.R. 28-19-350, Prevention of Significant Deterioration (PSD) of Air Quality, which adopts by reference 40 CFR 52.21. This unit is subject to BACT for PM, PM<sub>10</sub>, PM<sub>2.5</sub>, and CO<sub>2e</sub>.
- C. One compression ignition emergency diesel engine (engine make and model to be determined), rated at 250 kW, which shall burn only ultra-low sulfur diesel (ULSD, 15 ppm sulfur or less). This unit is subject to the requirements of 40 CFR Part 60 Subpart IIII and 40 CFR Part 63 Subpart ZZZZ. This diesel engine is subject to the requirements of K.A.R. 28-19-350, Prevention of Significant Deterioration (PSD) of Air Quality, which adopts by reference 40 CFR 52.21. This unit is subject to BACT for PM, PM<sub>10</sub>, PM<sub>2.5</sub>, and CO<sub>2e</sub>.
- D. One indirect dew point fuel-gas heater, rated at one (1) mmBtu/hr heat input, which shall only burn natural gas, for the purpose of heating the natural gas fuel prior to combustion in the Wartsila 4SLB RICE. This unit is subject to the requirements of 40 CFR Part 60 Subpart DDDDD. This heater is subject to the requirements of K.A.R. 28-19-350, Prevention of Significant Deterioration (PSD) of Air Quality, which adopts by reference 40 CFR 52.21. This heater is subject to BACT for PM, PM<sub>10</sub>, PM<sub>2.5</sub>, and CO<sub>2e</sub>.

**IV. Air Emission Estimates from the Proposed Activity**

The following table contains the PTE for air pollutants to be emitted from the proposed Project:

Table 1. Proposed Project Emissions and PSD Significant Emission Rates (SER)

<b>Pollutant <sup>a</sup></b>	<b>Project Potential Emissions (tons per year, tpy)</b>	<b>PSD Significant Emission Rate (tpy)</b>	<b>Exceeds Significant Emission Rate (SER)?</b>
NO <sub>x</sub>	36.7	40	No
CO	47.1	100	No
SO <sub>2</sub>	0.7	40	No
VOC	37.8	40	No
PM	28.4	25	Yes
PM <sub>10</sub> <sup>b</sup>	28.4	15	Yes
PM <sub>2.5</sub> <sup>b</sup>	28.4	10	Yes
CO <sub>2e</sub>	123,117	75,000	Yes
H <sub>2</sub> SO <sub>4</sub> Mist	0.1	7	No
Lead	2.2 x 10 <sup>-3</sup>	0.6	No

<sup>a</sup> NO<sub>x</sub> = Nitrogen oxides; SO<sub>2</sub> = Sulfur dioxide; CO = Carbon monoxide; PM = Total particulate matter; PM<sub>10</sub> = Particulate matter less than 10 micrometers (µm) in diameter; PM<sub>2.5</sub> = Particulate matter less than 2.5 µm in diameter; VOC = Volatile organic compounds; H<sub>2</sub>SO<sub>4</sub> = sulfuric acid; and CO<sub>2e</sub> = carbon dioxide equivalent.

<sup>b</sup> Filterable plus condensable.

**V. State Regulatory Requirements**

A. K.A.R. 28-19-30 through 32

1. K.A.R. 28-19-31(a) limits filterable particulate matter emissions from the dew point fuel-gas heater to 0.6 lb/MMBtu, except as provided in 28-19-11.
2. K.A.R. 28-19-31(b) limits visible contaminant emissions from dew point the fuel-gas heater to less than 20 percent opacity, except as provided in K.A.R. 28-19-11.

B. K.A.R 28-19-650(a)(3)

Opacity of any visible emissions from any new source is limited to less than 20 percent opacity, except as provided in K.A.R. 28-19-11.

C. Notification

Notify the Northwest District Office Air Program Field Staff at the Hays Office, 2301 East 13<sup>th</sup> Street, (785) 625-5663, within 30 days after construction is complete so that an evaluation may be conducted.

**VI. K.A.R. 28-19-350 Prevention of Significant Deterioration**

A. BACT Emission Limitations

1. The emission of pollutants from each EGU shall be no greater than the specified limitations listed below. 40 CFR Part 60 Subpart JJJJ requirements are included in a separate section of the permit as applicable. A violation of a BACT limitation is not necessarily a violation of an NSPS limitation. NSPS limitations are not applicable during startup, shutdown, or malfunction. For the purpose of demonstrating ongoing compliance with BACT-based emission limitations, startup ends 30 minutes after a start sequence is initiated.
  - a. The emission of PM/PM<sub>10</sub><sup>1</sup> /PM/ PM<sub>2.5</sub><sup>2</sup> shall not exceed 2.10 lb/hour at all times, except during startup and shutdown (3-hour averaging period).
  - b. The emission of CO<sub>2</sub>e shall not exceed 9,330<sup>3</sup> lb/hour at all times, except during startup and shutdown (annual averaging period).
  - c. The 12-month rolling average CO<sub>2</sub> emissions from the EGUs are limited to no more than 1.13 lb/kWh<sup>4</sup>; the total average EGU emissions for each month is determined as follows:

---

<sup>1</sup> The term "PM<sub>10</sub>" as used in this permit means that particulate matter (existing as solid, liquid, and gaseous form) emitted by a source that can be quantified by analysis either by EPA-approved Reference Methods 5 and 202 or by Methods 201A and 202 (with appropriate cyclone-sizing devices appropriate for quantification of PM<sub>10</sub>), or other such EPA approved test methods.

<sup>2</sup> The term "PM<sub>2.5</sub>" as used in this permit means that particulate matter (existing as solid, liquid, and gaseous form) emitted by a source that can be quantified by analysis either by EPA approved Reference Methods 5 and 202 or by Methods 201A and 202 (with appropriate cyclone sizing devices appropriate for the quantification of PM<sub>2.5</sub>) or other such EPA approved test methods.

<sup>3</sup> The CO<sub>2</sub> emitted is 9320 lb/hour; the remaining 10 lb/hour is the GHG equivalent attributed to methane and nitrous oxides.

<sup>4</sup> Fuel carbon dioxide is not included in this calculation. Startup fuel and energy produced during startups will not be included in this calculation.

$$ER = x * k * y \div z$$

Where:

ER= emission rate of carbon dioxide from the EGUs, lb/kW-hr;  
k = 3.667 lb carbon dioxide emitted per pound carbon in the fuel;  
x = lb carbon per cubic foot of natural gas, based on a monthly average fuel analysis by the pipeline supplier;  
y = total monthly cubic feet of natural gas burned in the EGUs; and  
z = total monthly gross kilowatt hours generated by the EGUs.

- d. The emission of PM<sub>10</sub>/ PM/PM<sub>2.5</sub> shall not exceed 2.55 lb/hr during startup (24-hour averaging period).
  - e. The emission of PM<sub>10</sub>/ PM/PM<sub>2.5</sub> shall not exceed 2.13 lb/hour during shutdown (24-hour averaging period).
  - f. The emission of CO<sub>2</sub>e shall not exceed 6,847 lb/hour during startup (24-hour averaging period).
2. The BACT emission of pollutants from the emergency diesel generator shall be no greater than limitations specified below, excluding periods of startup, shutdown, and malfunction.
    - a. The emissions of PM<sub>10</sub>/ PM/PM<sub>2.5</sub> shall not exceed 0.15 g/hp-hr.
    - b. BACT for CO<sub>2</sub>e shall be use of the most efficient engine that meets the facility's needs.
  3. The BACT emission of pollutants from the emergency fire pump shall be no greater than limitations specified below, excluding periods of startup, shutdown, and malfunction.
    - a. The emissions of PM<sub>10</sub>/ PM/PM<sub>2.5</sub> shall not exceed 2.20E<sup>-1</sup> g/hp-hr.
    - b. BACT for CO<sub>2</sub>e shall be use of the most efficient engine that meets the facility's needs.
  4. The BACT emissions of pollutants from the indirect dew point fuel-gas heater shall be no greater than limitations specified below, excluding periods of startup, shutdown, and malfunction.
    - a. The emissions of PM<sub>10</sub>/ PM/PM<sub>2.5</sub> shall not exceed 0.0075 lb/MMBtu.
    - b. BACT for CO<sub>2</sub>e shall be use of clean fuels, good combustion practices in accordance with the manufacturer's recommendations, proper maintenance, and tuning of the heater.

---

Fuel gas heater natural gas consumed is not included in the calculation.

B. Operating Limitations

1. Neither the emergency diesel generator nor the emergency fire pump shall be operated for more than 100 hours per year for testing and maintenance. Emergency use is not limited.
2. Only pipeline quality natural gas<sup>5</sup> shall be burned in the EGUs and the indirect fuel-gas heater.
3. Only ULSD (less than 15 ppm sulfur) shall be burned in the emergency fire pump and the emergency diesel generator.
4. The owner or operator shall operate and maintain all emission units, air pollution control equipment, and monitoring equipment in accordance with the manufacturer's recommendations, in a manner consistent with good combustion practices for minimizing emissions at all times, including periods of startup, shutdown, and malfunction, and in accordance with the manufacturer's recommendations.
5. Stack parameters for all equipment listed under Section III, Air Emissions Unit Technical Specifications, including but not limited to stack heights, stack diameters, exhaust temperatures, emission rates, and exit velocities, shall be consistent with data provided for the dispersion modeling analysis. Actual operational conditions shall be consistent with data provided for the dispersion modeling analysis.

C. Compliance

1. Compliance with A. BACT Emission Limitations 1 is established by performance testing as identified in D. Performance Testing, except for Limitation 1c.
2. Compliance with A. BACT Emission Limitation 1c is established by monitoring as identified in E. Monitoring Requirements 2.
3. Compliance with A. BACT Emission Limitations 2a, 2b, 3a, 3b, 4a, and 4b is established by the BACT analysis and emissions calculations submitted with the permit application.

D. Performance Testing Requirements

1. When conducting the compliance performance tests required by this permit, the reference test methods and procedures identified in K.A.R. 28-19-212 and/or EPA-approved test methods shall be used to demonstrate compliance with the limitations and conditions set forth in this permit.
2. For each EGU, an initial performance test shall be conducted within 180 days after startup to demonstrate compliance with each BACT emission limitation as specified in C. Compliance, except CO<sub>2</sub>e BACT limitations. Each engine shall be tested to demonstrate compliance with each limitation, except the CO<sub>2</sub>e BACT limitation, no less frequently

---

<sup>5</sup> Pipeline quality natural gas means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions and which is provided by a supplier through a pipeline. Pipeline quality natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 Btu per standard cubic foot. The H<sub>2</sub>S content shall be less than 4 ppm per 100 cubic feet of gas.

than every five years. This testing schedule shall not supersede performance test requirements for any applicable federal rules.

3. For each EGU, an initial performance test shall be conducted to demonstrate compliance with the CO<sub>2</sub>e emission limitation within 180 days after startup. The performance test shall consist of testing for CO<sub>2</sub> emissions only, which account for over 99% of total CO<sub>2</sub>e emissions. Emissions from each engine measured during the performance test shall be compared to a limit of 6,832 lb/hour CO<sub>2</sub> during startup, and 9,320 lb/hour CO<sub>2</sub> at all times except startup and shutdown. The owner or operator will monitor the overall performance of each EGU in accordance with good utility practice. Additionally, the owner or operator will perform one follow-up performance evaluation during each semi-annual (calendar) reporting period<sup>6</sup>; such evaluation should compare the engine's performance to data taken during the performance test, demonstrating that operation during the performance test is representative of the engine's normal operation. The evaluation should occur when the EGU is being operated above 90% load and in a steady-state condition (off automatic governor control); operating conditions, fuel quality, and maintenance conditions are within normal operating conditions.
4. Except for performance tests conducted to demonstrate compliance with startup and shutdown emission limitations, performance tests shall be conducted at no less than 90% of maximum load conditions.
5. A performance test protocol identifying proposed test methods and the proposed test schedule shall be submitted 60 days prior to testing and the protocol is subject to KDHE approval.

E. Monitoring Requirements

1. The owner or operator shall monitor the carbon content of the natural gas burned in the EGUs, based on a monthly average fuel analysis by the natural gas pipeline supplier; the total monthly cubic feet of natural gas burned in the EGUs as measured by a station grade fuel flow meter; and the gross power output as measured by a station grade watt-hour meter. This data shall be used to calculate compliance with A. BACT Emission Limitation 1c on a monthly basis.

F. Recordkeeping Requirements

1. The owner or operator shall maintain records of the hours of operation of the emergency diesel generator and the emergency fire pump.
2. The owner or operator shall maintain records of fuel analysis for all emission units demonstrating that only pipeline quality natural gas and ULSD were burned as required by this permit.
3. The owner or operator shall develop and maintain a record of all startup, shutdown, and malfunction activities, including malfunction in the operation of each unit and any malfunction of any air pollution control equipment. The record shall also include all maintenance activities including the nature of all repairs taken to correct malfunction incidents.

---

<sup>6</sup> An EGU operating less than 100 hours within a semi-annual reporting period will not be obligated to the performance evaluation.

4. The owner or operator shall keep records of all data and compliance calculations required by E. Monitoring Requirement 1.
5. The owner or operator shall keep records of the type and/or specifications of each emission unit installed at the proposed station.
6. The owner or operator shall keep records relating to maintaining good combustion practices for each emission unit in accordance with the manufacturer's recommendation to maintain efficiency of the combustion sources.
7. All records shall be retained for two years from the date of record.

**G. Reporting Requirements**

1. The owner or operator shall submit semiannual reports detailing compliance with the emission and operating limitations established in this permit; emissions measured or calculated shall be expressed in the same units as the BACT emission limitations. These reports shall be submitted within 30 days following the end of each calendar half-year and shall include:
  - a. The company name and address of the facility.
  - b. An identification of each emission unit being included in the semiannual report.
  - c. Beginning and ending dates of the reporting period.
  - d. A summary of startup, shutdown, malfunction events which occurred during the reporting period.
2. The owner or operator must notify KDHE by telephone, facsimile, or electronic mail transmission within two working days following the discovery of any failure of air pollution control equipment, process equipment, or process to operate in a normal manner which results in an increase in emissions above any allowable emission limitation. In addition, the owner or operator must notify KDHE in writing within ten days of any such failure. The written notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial malfunction, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed, and the methods utilized to mitigate emissions and restore normal operation.
3. If significant changes are made, or modeling parameters are not representative of site conditions, the owner or operator shall document compliance with the applicable NAAQS and allowable PSD increment consumption and submit documentation of compliance to KDHE prior to making the change(s). KDHE has final authority in determining what constitutes a significant change. If modeling indicates a potential NAAQS or increment exceedance, then mitigation shall be required.

**VII. 40 CFR Part 60 Subpart III**

**A. Emission Limitations**

1. Pursuant to 40 CFR 60.4205(b), the owner or operator of the emergency diesel engine shall comply with applicable emission standards in 60.4202 for all pollutants, for the same model year and maximum engine power. The stationary emission manufacturer

must certify the emergency diesel engine to the same model year and maximum engine power in 40 CFR 89.112 and 40 CFR 89.113.

2. Pursuant to 40 CFR 60.4205(c), the owner or operator of the emergency fire pump engine shall comply with the applicable emission standards in Table 4 of 40 CFR 60 Subpart III. The owner or operator shall also meet the requirements of 60.4206. In accordance with Table 4 of 40 CFR 60 Subpart III, the emergency fire pump engine NMHC+ NO<sub>x</sub> emissions shall not exceed 4.0 g/kW-hr (3.0 g/hp-hr), CO emissions shall not exceed 5.0 g/kW-hr (3.7 g/hp-hr), and PM emissions shall not exceed 0.30 g/kW-hr (0.22 g/hp-hr) over the life of the engine. The engine shall be certified by the manufacturer to meet these emission limits per 40 CFR 60.4202(d).

B. Operating Limitations

1. For the emergency fire pump engine and the emergency diesel engine, the owner or operator shall comply with applicable diesel fuel requirements of 40 CFR 60.4207.
2. For the emergency fire pump engine, the provisions of 40 CFR 60.4211(f) apply. Maintenance checks and readiness testing is limited to 100 hours per year, of which up to 50 hours per year may be for non-emergency situations. There is no time limit on the use of the emergency fire pump in emergency situations.

C. Monitoring Requirements

If the emergency fire pump engine and/or the emergency diesel engine do not meet the standards applicable to non-emergency engines, the owner or operator must install a non-resettable hour meter prior to startup of the engine, as specified in 40 CFR 60.4209.

D. Compliance Requirements

For the emergency fire pump engine and the emergency diesel engine, the owner or operator must install, configure, operate, and maintain the engine and control device according to the manufacturer's emission-related written instructions. The owner or operator must not change emission-related settings in a way that is not permitted by the manufacturer, or thereafter demonstrate compliance as specified at 40 CFR 60.4211(g)(2).

E. Recordkeeping Requirements

For the emergency fire pump engine and the emergency diesel engine, the owner or operator must keep records of the emergency and non-emergency operations of the engine through a non-resettable hour meter if it does NOT meet the standards applicable to the non-emergency engines in the applicable model year. The times of operation and the reasons for operation must be recorded, as specified in 40 CFR 60.4214(b).

F. Reporting Requirements

If the emergency diesel engine is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in 60.4211(f)(2)(ii) and (iii) or that operates for the purposes specified in 60.4211(f)(i), you must submit an annual report according to the requirements in 60.4214(d).

G. Applicability of Federal Rule General Provisions

For the emergency fire pump engine and the emergency diesel engine, 40 CFR 60.4218 and Table 8 identify the Subpart A requirements that are applicable.

H. Additional Provisions

The owner or operator shall comply with all requirements of 40 CFR Part 60 Subpart III. These requirements are summarized in this permit. If a conflict exists between the federal rule and the permit, the requirements of the federal rule shall take precedence.

**VIII. 40 CFR Part 60 Subpart JJJJ**

A. Emission Limitations

1. For each EGU, the owner or operator shall comply with the requirements of 40 CFR 60.4233(e) and 60.4234. These regulations require the owner or operator to meet the applicable emission limitations in Table 1 of 40 CFR 60 Subpart JJJJ for the EGUs over their entire lives. Table 1 of 40 CFR 60 Subpart JJJJ provides the following emission limitations for the EGUs:

- a. Emission of NO<sub>x</sub> is limited to no more than 1.0 g/hp-hour or 82 ppmvd at 15% O<sub>2</sub>.
- b. Emission of CO is limited to no more than 2.0 g/hp-hour or 270 ppmvd at 15% O<sub>2</sub>. Owners or operators of engines located at major sources that are meeting the requirements of 40 CFR Part 63, Subpart ZZZZ Table 2a do not have to comply with this standard as specified in Table 1.
- c. Emission of VOC is limited to no more than 0.7 g/hp-hour or 60 ppmvd at 15% O<sub>2</sub>.

B. Compliance Requirements

1. For each EGU that is not certified, performance testing shall be conducted in accordance with 40 CFR 60.8(a) within 60 days of reaching maximum production rate, but not later than 180 days after initial startup.
2. For each EGU that is not certified, and as required by 40 CFR 60.4243(b)(2)(ii), the owner or operator must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. The owner or operator shall comply with the requirements of 40 CFR 60.4243(b)(2)(ii) to conduct an initial performance test and conduct subsequent performance testing every 8760 hours or three years, whichever comes first, thereafter to demonstrate compliance.

C. Performance Testing Requirements

For each EGU that is not certified, each performance test must be conducted following the requirements of §60.4244 and according to the requirements in 40 CFR 60.8 and under the conditions specified in Table 2.

D. Notification, Reporting, and Recordkeeping Requirements

1. For each EGU, the owner or operator shall comply with the recordkeeping requirements of 40 CFR 60.4245(a).
2. For each EGU, the owner or operator shall comply with the notification requirements of 40 CFR 60.4245(c).

3. For each EGU, the owner or operator shall comply with the reporting requirement outlined in 40 CFR 60.4245(d), which requires the owner or operator to submit a copy of each performance test within 60 days after the test has been completed.

E. Applicability of Federal Rule General Provisions

For the EGUs, the owner or operator is required to follow 40 CFR Part 60 Subpart A General Provisions requirements outlined in 40 CFR 60.4246 and in Table 3, which excludes the monitoring requirements of 40 CFR 60.13 and the general control device requirements in 40 CFR 60.18.

F. Additional Provisions

The owner or operator shall comply with all requirements of 40 CFR Part 60 Subpart JJJJ. These requirements are summarized in this permit. If a conflict exists between the federal rule and the permit, the requirements of the federal rule shall take precedence.

**IX. 40 CFR Part 63 Subpart ZZZZ**

A. Emission Limitations

For each EGU, the owner or operator shall comply with the requirements 40 CFR 63.6600(b) and Table 2a. Each EGU emission control system is required to reduce CO emissions by 93 percent or more; or limit the concentration of formaldehyde in the exhaust to 14 ppmvd or less at 15 percent O<sub>2</sub>.

B. Operating Limitations

For each EGU, the owner or operator shall comply with the requirements 40 CFR 63.6600(b) and Table 2b.

C. Performance Testing Requirements

1. For each EGU, the owner or operator shall comply with 40 CFR 63.6610(a) and Table 4. The owner or operator must conduct the initial performance test within 180 days after the compliance date that is specified in 40 CFR 63.6595 and according to the provisions of 40 CFR 63.7(a)(2). Requirements are outlined in Table 4, Item 1a for compliance with the requirement to reduce CO emissions, and are outlined in Table 4, Item 3a for compliance with the requirement to limit the concentration of formaldehyde in the exhaust.
2. For each EGU, the owner or operator shall comply with the requirements of 40 CFR 63.6615 to conduct subsequent performance tests as specified in Table 3. Requirements are outlined in Table 3, Item 1 for compliance with the requirement to reduce CO emissions, and are outlined in Table 3, Item 3 for compliance with the requirement to limit the concentration of formaldehyde in the exhaust.
3. For each EGU, the owner or operator shall follow the performance test and other procedures and requirements of 40 CFR 63.6620.

D. Monitoring, Installation, Collection, Operation, and Maintenance Requirements

1. For each EGU, the owner or operator shall comply with the requirements of 40 CFR 63.6625(b) to install a continuous parameter monitoring system (CPMS) as specified in

Table 5. The owner or operator must install, operate, and maintain each CPMS according to the requirements of 40 CFR 63.6625(b).

2. For each EGU, the owner or operator shall comply with the requirements of 40 CFR 63.6625(h) to minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to conditions other than startup in Table 2a shall apply.

E. Initial Compliance

1. For the EGUs, the owner or operator shall comply with the following requirements of 40 CFR 63.6630 to demonstrate initial compliance with emission limitations and operating limits:
  - a. Comply with each emission and operating limitation that applies in Table 5.
  - b. Establish each operating limitation in Table 2b that applies.
  - c. Submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in 40 CFR 63.6645.

F. Continuous Compliance

1. For each EGU, the owner or operator must be in compliance with the applicable emission limitations and operating limitations in 40 CFR 63 Subpart ZZZZ at all times as provided in 40 CFR 63.6605.
2. 40 CFR 63.6605(b) requires that the owner or operator must operate and maintain the engines, including their associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to KDHE which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.
3. For each EGU, the owner or operator shall comply with the requirements of 40 CFR 63.6635 to monitor and collect data to demonstrate continuous compliance.
4. For each EGU, except for monitor malfunctions, associated repairs, required performance evaluations, and required quality assurance or control activities, the owner or operator must monitor continuously at all times that the EGU is operating. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.
5. For each EGU, the owner or operator may not use data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities in data averages and calculations used to report emission or operating levels. The owner or operator must use all the valid data collected during all other periods.
6. For each EGU, the owner or operator shall comply with the following requirements of 40 CFR 63.6640 to demonstrate continuous compliance with emission limitations and operating limitations:
  - a. According to 40 CFR 63.6640(a), the owner or operator must demonstrate continuous compliance with each emission limitation and operation limitation in

Tables 2a and 2b according to the methods specified in Table 6 of 40 CFR 63 Subpart ZZZZ.

- b. According to 40 CFR 63.6640(b), the owner or operator must report each instance in which the EGU does not meet each emission limitation or operating limitation in Tables 2a and 2b or 40 CFR 63 Subpart ZZZZ. These instances are deviations from the emissions and operating limitations in 40 CFR 63 Subpart ZZZZ. These deviations must be reported according to the requirements in 40 CFR 64.6650. If the catalyst is changed, the owner or operator must reestablish the values of the operating parameters measured during the initial performance test. The owner or operator must also conduct a performance test to demonstrate compliance with the required emission limitation applicable to the EGU.
- c. According to 40 CFR 63.6640(d), deviations from the emission or operating limitations that occur during the first 200 hours of operation from the initial startup (engine burn-in period) are not violations.
- d. The owner or operator must report each instance in which the applicable requirements in Table 8 to 40 CFR 63 Subpart ZZZZ are not met.

G. Notification Requirements

1. For the emergency diesel generator and the emergency fire pump, 40 CFR 63.6590 requires the facility to meet the requirements of Subpart ZZZZ and Subpart A by following the initial notification requirements of 40 CFR 63.6645(f).
2. For each EGU, the owner or operator shall comply with the notification requirements of §63.6645. These include but are not limited to the following:
  - a. According to 40 CFR 63.6645(a), submit all of the notifications required at 40 CFR 63.7(b) and (c), 63.8(e), (f)(4) and (f)(6), 63.9(b) through (e), and (g) and (h) by the dates specified.
  - b. According to 40 CFR 63.6645(c), submit an Initial Notification not later than 120 days after the facility becomes subject to 40 CFR Part 63 Subpart ZZZZ.
  - c. According to 40 CFR 63.6645(g), submit a Notification of Intent to conduct a performance test at least 60 days before the performance test is scheduled to begin as required in 40 CFR 63.7(b)(1).
  - d. According to 40 CFR 63.6645(h), submit a Notification of Compliance Status according to 40 CFR 63.9(h)(2)(ii). For each initial compliance demonstration required in Table 5 that includes a performance test conducted according to the requirements in Table 3, the owner or operator shall submit the Notification of Compliance Status, including the performance test results, before the close of business on the 60th day following the completion of the performance test according to 40 CFR 63.10(d)(2).

H. Reporting Requirements

For each EGU, the owner or operator shall comply with the applicable reporting requirements of 40 CFR 63.6650 and in Table 7 of 40 CFR 63 Subpart ZZZZ.

I. Recordkeeping Requirements

1. For each EGU, the owner or operator shall comply with the applicable recordkeeping requirements of 40 CFR 63.6655 and in Table 6 of 40 CFR 63 Subpart ZZZZ.
2. For each EGU, the owner or operator must keep records in the form and for the length of time specified in 40 CFR 63.6660.

J. Applicability of Federal Rule General Provisions

For each EGU, the owner or operator is required to follow the applicable requirements of 40 CFR Part 63 Subpart A General Provisions as specified in 40 CFR 63.6665 and outlined in Table 8 of 40 CFR 63 Subpart ZZZZ.

K. Additional Provisions

The facility shall comply with all requirements of 40 CFR Part 63 Subpart ZZZZ. Requirements are summarized in this permit. If a conflict exists between the federal rule and the permit, requirements of the federal rule shall take precedence.

**X. 40 CFR Part 63 Subpart DDDDD**

A. Work Practice Standards

1. The owner or operator shall meet the requirements of 63.7500 at all times the dew point fuel-gas heater is operating.
2. The owner or operator shall meet each work practice standard in Table 3 that applies to the dew point fuel-gas heater as required by 63.7500(a)(1). Table 3 requires the owner or operator to conduct a tune-up of the fuel-gas heater every 5 years as specified in 63.7540.
3. At all times, the owner or operator must operate and maintain the dew point fuel-gas heater in a manner consistent with safety and good air pollution control practices for minimizing emissions as required by 63.7500(a)(3).

B. Initial Compliance

1. As required by 63.7510(g), the owner or operator of the dew point fuel-gas heater must demonstrate initial compliance with the applicable work practice standards in Table 3 within the applicable 5 year schedule as specified in 63.7540(a) following the initial compliance date specified in 63.7495(a). Thereafter, the owner or operator shall complete the 5-year tune-up as specified in 63.7540(a) and 63.7515(d).
2. As required by 63.7530(d), the owner or operator of the dew point fuel-gas heater must submit a signed statement in the Notification of Compliance Status Report that indicates that a tune-up of the unit was conducted.
3. As required by 63.7530(f), the owner or operator must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in 64.7545(e).

C. Continuous Compliance

1. The owner or operator shall demonstrate continuous compliance with requirements of this subpart according to the methods and schedule specified in 63.7540(a).

2. As required by 63.7540(a)(12), the owner or operator must conduct a tune-up of the dew point fuel-gas heater every 5 years as specified in paragraphs 63.7540(a)(10)(i) through (vi) to demonstrate continuous compliance.
3. The owner or operator must report each instance in which the requirements in Table 3 for the dew point fuel-gas heater were not met. These instances are deviations and must be reported according to the requirements in 63.7550.

D. Notification, Reports, and Records

1. The owner or operator shall submit all of the notifications in 63.7545, and 63.9(b) through (h) if applicable by the dates specified.
2. The owner or operator shall submit reports specified in 63.7550 that apply and by the dates specified.
3. The owner or operator shall keep records as specified in 63.7555, and in the form and for the length of time specified in 63.7560.

E. Applicability of Federal Rule General Provisions

For the fuel-gas heater, the owner or operator is required to follow the applicable requirements of 40 CFR Part 63 Subpart A General Provisions as specified in 40 CFR 63.7565 and outlined in Table 10 of 40 CFR 63 Subpart DDDDD.

F. Additional Provisions

The owner or operator shall comply with all requirements of 40 CFR Part 63 Subpart DDDDD. These requirements are summarized in this permit. If a conflict exists between the federal rule and the permit, the requirements of the federal rule shall take precedence.

**XI. 40 CFR Part 72 Subpart A**

The EGUs are considered to be new utility units under 40 CFR 72.6. 40 CFR 72.7(b) states that any new utility unit that has not previously lost an exemption under 40 CFR 72.7(f)(4) and that meets provisions of 40 CFR 72.7(a) shall be exempt from the Acid Rain Program, except for the provisions of 40 CFR 72.2 through 72.6, and 72.10 through 72.13. This exemption shall be effective on January 1 of the first full calendar year for which the unit meets these requirements. By December 31 of the first year for which the unit is to be exempt, a statement signed by the designated representative or certifying official shall be submitted to the KDHE Bureau of Air. The statement shall identify the unit, state the nameplate capacity of each generator served by the unit and the fuels currently burned or expected to be burned by the unit and their sulfur content by weight, and state that the owners and operators of the unit will comply with 40 CFR 72.7(f).

**XII. Permit General Provisions**

- A. This document will become void if construction or modification has not commenced within 18 months of the effective date, or if the construction or modification is interrupted for a period of 18 months or longer. [K.A.R. 28-19-301(c)].
- B. A construction permit or approval must be issued by KDHE prior to commencing any construction or modification of equipment or processes which results in an increase of potential-to-emit equal to or greater than the thresholds specified at K.A.R. 28-19-300(a) and (b).

- C. Upon presentation of credentials and other documents as may be required by law, representatives of KDHE (including authorized contractors of KDHE) shall be allowed to:
1. enter upon the permittee's premises where a regulated facility or activity is located or conducted or where records shall be kept under conditions of this document;
  2. have access to and copy, at reasonable times, any records that shall be kept under conditions of this document;
  3. inspect at reasonable times, any facilities, equipment (including monitoring and control equipment) practices or operations regulated or required under this document; and
  4. sample or monitor, at reasonable times, for the purposes of assuring compliance with this document or as otherwise authorized by the Secretary of KDHE, any substances or parameters at any location.
- D. The emission unit or stationary source, which is the subject of this document, will be operated in compliance with all applicable requirements of the Kansas Air Quality Act and the federal Clean Air Act.
- E. This document is subject to periodic review and amendment as deemed necessary to fulfill the intent and purpose of the Kansas Air Quality Statutes and Regulations and rules promulgated in accordance therewith.
- F. This document does not relieve the permittee of the obligation to obtain any approvals, permits, licenses, or documents of sanction, which may be required by other federal, state or local government agencies.

**Permit Writer**

---

Gerald McIntyre, P.E.  
Professional Environmental Engineer  
Air Permitting Section

---

Date Signed

GMc:saw  
c: Larissa Parker, NWDO  
C-11921