

ADDENDUM

IFB Number: 264-12-3

Addendum No: 1

Date Posted: September 21, 2011
Closing Date: 2:00 PM, October 10, 2011

Procurement Officer: Kelly Chilson

Telephone: 785-296-1519

E-Mail Address: kchilson@kdhe.state.ks.us

Item: Project Safe At Home – Lead Hazard Reduction

Conditions:

Property # 1 855 Chautauqua

1. Paint only the wood body surfaces of garage
2. Clarification: This house has three (3) bedrooms

Property # 2 1639 North Green

1. Paint all exterior wood trim

Property # 3 612 North Green

1. Clarification: This house has three (3) bedrooms

Property # 4 2266 South Greenwood

1. Disregard any work on bathroom window

Property # 5 6111 Oakwood 532 Ellis

1. Repair soffit and fascia as need
2. Install new gutters and downspouts on side "c" and rear of house side "B"

Property # 6 2415 North Chautauqua

1. Replace window in garage side "D"

Property 7 3325 North Park Place

1. No Changes

Property # 8 2900 South Clifton

1. Do not paint, repair or replace any components of front porches
2. Replace exterior door per specification, wet scrape, prime and paint frames if install slab doors. If slab doors are installed also install weather stripping. **(1 door side "C", 1 door side "D" and 2 doors side "A")**
3. Install new seamless gutters and downspouts

Property # 9 1426 North Emporia

1. Till soil, plant grass seed and cover with straw on **side "C" only**

General Note:

1. **As per Wichita City Code All Windows Installed in Bathrooms must be Tempered Glass**

Kelly Chilson, Director
Purchasing Services
Kansas Department of Health & Environment
1000 SW Jackson, Suite 570
Topeka KS 66612